CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.13/CSR-05/341/CEMENT/2017-18 Date: 22.05.2017

TEST REPORT ON CEMENT

* Customer	:	**Asst. Executive Engineer,** Project Sub Division, Dasarahalli Zone, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of Work	:	Construction of RCC drain and CC roads at 3rd main and adjacent cross roads in Ravindra Nagara Ward No.13, BBMP, Bangalore.
* Reference	:	AEE/PSD/PR/01/2017-18 Dated: 20.05.2017
* Sample ID	:	Cement
Sample Received on	:	20.05.2017
Period of Testing	:	20.05.2017 to 22.05.2017

The results of the tests conducted on the cement sample are as follows:

Sl. No	Descriptions	Test Method as per IS	Test Result	Requirements as per IS: 8112-2013
1	Standard Consistency	IS-4031 (Part -4) 1988 (RA-2014)	28.00 %	-
2	a) Initial Setting Time	IS-4031 (Part -5) 1988 (RA-2014)	160 Minutes	Not Less than 30 Minutes
	b) Final Setting Time	IS-4031 (Part -5) 1988 (RA-2014)	490 Minutes	Not More than 600 Minutes
3	Soundness by Le Chartlier Method	IS-4031 (Part-3) 1988 (RA-2014)	1 mm	Not more than 10mm

*Information is furnished by the Customer/Representative.

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

****

VIDYARANI P.K.
Technical Manager

AE-(V)

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone.
Bruhat Bengaluru Mahanagara Palike

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.13/CSR-05/341/SAND-Gradation/2017-18 22.05.2017

TEST REPORT ON SIEVE ANALYSIS OF FINE AGGREGATES

* Customer	:	**Asst. Executive Engineer,** Project Sub Division, Dasarahalli Zone, BBMP,
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of Work	:	Construction of RCC drain and CC roads at 3rd main and adjacent cross roads in Ravindra Nagara Ward No.13, BBMP, Bangalore.
* Reference	:	AEE/PSD/PR/01/2017-18 Dated: 20.05.2017
* Sample ID	:	Fine Aggregates
Technical Reference	:	IS : 2386 (Part 1) - 1963 (RA-2011)
Sample Received On	:	20.05.2017
Date of Testing	:	22.05.2017

Total Wt. of Aggregates in gms = **1000**

IS Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS 383-1970 (RA- 2011)			
		Zone-I	Zone-II	Zone-III	Zone-IV
10	100	100	100	100	100
4.75	96.50	90-100	90-100	90-100	95-100
2.36	76.70	60-95	75-100	85-100	95-100
1.18	55.20	30-70	55-90	75-100	90-100
600 Micron	25.20	15-34	35-59	60-79	80-100
300 Micron	15.00	5-20	8-30	12-40	15-50
150 Micron	7.80	0-10	0-10	0-10	0-15

* Information is furnished by the Customer/Representative

Remarks : This sample is under Zone-I specific limits.

Note:

⇒The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒Any Query regarding the report must be reported within 30 days from the date of testing.

****

VIDYARANI P.K.
Technical Manager

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone,
Bruhat Bangaluru Mahanagara Palike

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.13/CSR-05/341/AGG/GR/2017-18 22.05.2017

TEST REPORT ON SIEVE ANALYSIS OF COARSE AGGREGATES

* Customer	:	**Asst. Executive Engineer,** Project Sub Division, Dasarahalli Zone, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of Work	:	Construction of RCC drain and CC roads at 3rd main and adjacent cross roads in Ravindra Nagara Ward No.13, BBMP, Bangalore.
* Reference	:	AEE/PSD/PR/01/2017-18 Dated: 20.05.2017
* Sample ID	:	Coarse Aggregates (40mm)
Technical Reference	:	IS : 2386 (Part 1) -1963 (RA-2011)
Sample Received on	:	20.05.2017
Date of Testing	:	22.05.2017

Total Wt. of Aggregates in gms= **5000**

IS Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS 383-1970 (RA- 2011)	
		Graded	Single Sized
80	100	100	-
63	100	-	100
40	97.22	95-100	85-100
20	39.28	30-70	0-20
10	16.70	10-35	0-5
4.75	4.16	0-5	-

* Information is furnished by the Customer/Representative

Remarks : This sample is under graded specific limits.

Note:

⇒The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒Any Query regarding the report must be reported within 30 days from the date of testing.

****

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone,
Bruhat Bengaluru Mahanagara Palike

VIDYARANI P.K.
Technical Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

JAS-ANZ BSCIC ISO 9001 REGISTERED

Job No.: CTCE/BBMP/KRIDL/W.No.13/GSB-II/GR/2017-18 24.05.2017

TEST REPORT ON GRADATION FOR COARSE GRADED GARNULAR SUB BASE

* Customer	:	**Asst. Executive Engineer,** Project Sub Division, Dasarahalli Zone, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of work	:	Construction of RCC drain and CC roads at 3rd main and adjacent cross roads in Ravindra Nagara Ward No.13, BBMP, Bangalore.
* Reference	:	AEE/PSD/PR/01/2017-18 Dated: 20.05.2017
* Sample ID	:	Coarse Graded-II
Technical Reference	:	IS : 2720 (Part - 4), MORTH Table : 400-02
Date of Testing	:	24.05.2017

Oven Dry Wt (gm) : 5000

Is Sieve Size in mm	Weight Retained (gm)	Cumulative Weight Retained (gm)	Cumulative % of Retained	Cumulative % of Passing	Specified Limits
53	-	-	-	100	100
26.5	2240	2240	44.80	55.20	50-80
4.75	1595	3835	76.70	23.30	15-35
0.075	765	4600	92.00	8.00	0-10
PAN	400				
Total	5000				

* Information is furnished by the Customer/Representative

Remarks: Satisfies MORTH Specifications as per Table 400-2, Grading II

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone,
Bruhat Bangalore Mahanagara Palike

Civil-tech Consultants & Engineers
#23/14, 7th Cross 3rd Stage 4th Block,
Shakthi Ganapathinagar,
Basaveshwaranagar, Bangalore-560 079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

JAS-ANZ BSCIC ISO 9001 REGISTERED

Job No.: CTCE/BBMP/KRIDL/W.No.13/GSB-II/AL/2017-18 Date 24.05.2017

TEST REPORT ON ATTERBERG LIMITS FOR GRANULAR SUB BASE

*Customer	:	**Asst. Executive Engineer,** Project Sub Division, Dasarahalli Zone, BBMP, Bangalore.
*Agency	:	**Technical Manager,** KRIDL, Bangalore.
*Name of work	:	Construction of RCC drain and CC roads at 3rd main and adjacent cross roads in Ravindra Nagara Ward No.13, BBMP, Bangalore.
*Reference	:	AEE/PSD/PR/01/2017-18 Dated: 20.05.2017
Sample ID	:	GSB- (Coarse graded-II)
Technical Reference	:	IS : 2720 (Part - 5) 1985 (RA-2010), MORTH Table : 400-01
Date of Testing	:	24.05.2017

Sl. No.	Particulars	Test Results	Standards as per Specifications
1	Liquid Limit, %	23.00	25.0% Maximum.
2	Plasticity Index, %	Non Plastic	6.0% Maximum.

*Information is furnished by the Customer/Representative.

Note:

⇒The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒Any Query regarding the report must be reported within 30 days from the date of testing.

****

Civil-tech Consultants & Engineers
#23/14, 7th Cross 3rd Stage 4th Block,
Shakthi Ganapathinagar,
Basaveshwaranagar, Bangalore-560 079.

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone,
Bruhat Bengaluru Mahanagara Palike

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

JAS-ANZ BSCIC ISO 9001 REGISTERED

Job No.: CTCE/BBMP/KRIDL/W.No.13/Steel/2017-18

22.05.2017

TEST REPORT ON REINFORCEMENT STEEL

* Customer	:	**Asst. Executive Engineer,** Project Sub Division, Dasarahalli Zone, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of work	:	Construction of RCC drain and CC roads at 3rd main and adjacent cross roads in Ravindra Nagara Ward No.13, BBMP, Bangalore.
* Reference	:	AEE/PSD/PR/01/2017-18 Dated: 20.05.2017
* Samples ID	:	10 mm Bar
Technical Reference	:	IS: 1786-2008 (RA-2013)
Date of Testing	:	22.05.2017

Sl No	Nominal size (dia) (mm)	Mass per metre (Kg/mtr)	TENSILE STRENGTH			Bend Test	Rebend Test
			0.20% proof stress/Yield stress N/mm2	Tensile strength (Ultimate stress) N/mm2	Elongation percent gauge length		
1	10	0.62	520	562	13.3	O.K	O.K

*Information is furnished by the Customer/Representative.

Note:

⇒The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒Any Query regarding the report must be reported within 30 days from the date of testing.

****

Civil-tech Consultants & Engineers
#23/14, 7th Cross 3rd Stage 4th Block,
Shakthi Ganapathinagar,
Basaveshwaranagar, Bangalore-560 079.

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone,
Bruhat Bengaluru Mahanagara Palike

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.13/CSR-05/341/Cube/2017-18 20.06.2017

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

* Customer	:	**Asst. Executive Engineer,** Project Sub Division, Dasarahalli Zone, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of the work	:	Construction of RCC drain and CC roads at 3rd main and adjacent cross roads in Ravindra Nagara Ward No.13, BBMP, Bangalore.
* Reference	:	AEE/PSD/PR/01/2017-18 Dated: 20.05.2017
* Sample ID	:	RCC Drain Concrete
Technical Reference	:	IS: 516-1959 (RA-2013)
Size of cubes	:	150mmx150mmx150mm
Cross Sectional Area	:	22500 mm^2
* Grade of Concrete	:	M_{20}
Compressive Strength as on	:	28^{th} day
Sample Received on	:	20.06.2017

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	23.05.2017	20.06.2017	8.123	475.5	21.13
2	23.05.2017	20.06.2017	8.235	490.3	21.79
3	23.05.2017	20.06.2017	8.300	510.7	22.70

*Information is furnished by the Customer/Representative.

Note:

⇒The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒Any Query regarding the report must be reported within 30 days from the date of testing.

****

VIDYARANI P.K.
Technical Manager

AE (P)

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone,
Bruhat Bengaluru Mahanagara Palike

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com